

Issue Date: June 7, 2017

FROM: ROSSER INTERNATIONAL, INC.  
1555 Peachtree Street, N.E., Suite 800  
Atlanta, Georgia 30309

TO: BIDDERS  
Barrow County Jail Kitchen Floor Renovation Project  
Winder, Georgia

**ADDENDUM NO. 04**

THIS ADDENDUM is hereby made a part of the Construction Documents dated May 4, 2017 on the subject work as though originally included therein. Prospective Bidders shall acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification. The following amendments, additions and/or corrections shall govern this work.

This Addendum is in two parts as follows:

- Part II - Pertaining to Drawings
- Part III - Pertaining to Questions

**PART II - CHANGES AND/OR CLARIFICATIONS TO THE PROJECT DRAWINGS**

Note: Because of the nature of the following revisions and time limitations, the following drawings are not being altered or issued to show the referenced revisions; these drawings as herein revised are made a part of the contract requirements.

A4-1 **DRAWING SHEET – A1.01 KITCHEN FLOOR PLAN**

- a. Add the following note to this drawing:  
“NOTE: Floor drains to remain and will not be replaced unless it is discovered that existing damage to the drain prevents the installation of the floor system, at which time means of correction will be determined and issued by the Architect.”

**PART III – PRE-BID QUESTIONS**

A4-2 **Question:**  
Would it be possible to provide a floor plan diagram showing which kitchen equipment that you will want us to remove and replace?

**Response:**  
No, refer to Construction Documents and item #10 in the Meeting Minutes in Addendum No. 02. Remove all equipment except the dishwasher.

A4-3 **Question:**  
Will the existing floor drains be replaced or remain in place?

**Response:**  
See this Addendum, item A4-1, for change to Construction Documents Drawings.

END OF QUESTIONS

**END OF THIS ADDENDUM**