



Fire Chief Brett Skinner

Fire Marshal Capt. Jessie Knight

*Barrow County Fire Department, 222 Pleasant Hill Church Road, NE,
Winder, Georgia 30680*

FIREWORKS SALES TENT OR STAND PERMIT REQUIREMENTS

Barrow County Fire Marshal's Office in pursuant to National Fire Protection Association Code 1124 for the Manufacture, Transportation, Storage, and Retail Sales of Fireworks and Pyrotechnic Articles section 7.3 requires a permit for the sale of fireworks at a temporary structure or tent.

Applicant Shall Provide:

1) A site plan with the correct address showing the location of the stand or tent on the site and indicate the minimum separation distance. Section 7.7.

- a. 20 feet from buildings, combustibles, adjacent tents or stands, and storage container.
- b. 10 feet from vehicle parking.

c. 50 feet from vehicle fuel dispensing areas, above ground storage tanks of flammable and combustible liquids and retail propane-dispensing or CNG dispensing.

2) Location of any fuel fired generators and fuel supply storage; they shall be a minimum of 20 feet from the stand or tent. Section 7.11.3

- a. Generators can only have a fuel cell of 5 gallons for class II or III combustible liquids
- b. Generators can only have a fuel cell of 2 gallons for class I (gasoline) flammable liquids.

3) Floor plan for the tent or stand showing the exit locations and aisle arrangement and widths.

- a. Aisle width minimum 48" (inches). Section 7.8.5.1
- b. A minimum of 2 (two) exits shall be provided. Section 7.8.3.2

c. Exit signs are required to be posted. If hours of operation for the stand or tent are after dusk, internally illuminated exits signs and emergency lighting shall be required. Section 7.9

d. All exit doors in stands shall provide a minimum of 32" clear width and tents shall provide a minimum clear opening of 44". Section 7.8.6

- e. Height of sales displays shall not exceed 6 (six) feet. Section 7.10.2

- f. Shelving details shall be provided (Flame breaks if required). Section 7.10.3

- g. Firework fuses shall be covered as defined by NFPA 1124. Section 7.10.4

4) Security of the tent, stand or portable storage container/building shall be provided. Provide on company letterhead the hours of operation and how the fireworks will be secured during nonoperating hours. Section 7.12.3 5) Signs posted:

a. At the cash register/check-out, a sign stating, "MUST BE 18 YEARS OF AGE TO PURCHASE FIREWORKS". OCGA Title 25 Chapter 10.

b. On the exterior of each side of the tent or stand a sign shall be posted with lettering of at least 4" on a contrasting background stating "NO FIREWORKS DISCHARGE WITHIN 300 FEET". Section 7.6.4

c. At the entrances to the tent or stand a sign shall be posted with lettering of at least 2" on a contrasting background stating "FIREWORKS—NO SMOKING". Section 7.6.5

6) Fire Extinguishers shall be provided: Every facility shall be provided with one 5 lb. multipurpose type ABC dry chemical extinguisher and one pressurized water extinguisher with a minimum rating of 2A. Section 7.5.2 Exception: one is required for tent/stands less than 200 square feet. 7) Flame spread certificate for any tents/canopies.

******Additional requirements may be required upon Fire Marshal plan review and site inspection******